

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

PEDRO BIRBA
VICE-PRESIDENT

VAN AMBATIELOS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

Solar Industries, Incorporated
Post Office Box 27337
Tucson, AZ 85726-7337

Attn: Carl Shelton
(520) 519-8258

RESEARCH REPORT: RR 24785
(CSI #08620)

BASED UPON ICC ES LEGACY
REPORT NO. ER-4063

REEVALUATION DUE DATE:
July 1, 2009

GENERAL APPROVAL - Reevaluation - Skyview Skylights.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Legacy Report No. ER-4063, dated May 1, 2001, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ER-4063 which are excluded on the attached copy have been removed by the Los Angeles Building Department as not being included in this approval.

The approval is subject to the following conditions:

1. The aggregate area of the skylights installed in a roof shall not exceed 25% of the floor area of the room or space sheltered by the roof.
2. The skylights shall be installed with a minimum curb height of 4-inches measured above the plane of the roof.
3. Location and separation of skylights shall comply with the requirements of Sections 91.2603.7.1 of the 2002 Los Angeles City Building Code.

RR 24785
Page 1 of 2

Solar Industries, Incorporated
RE: Skyview Skylights

DISCUSSION

This approval is based on load tests conducted in accordance with ASTM E-330.

The plastic domes are manufactured from Optix® Acrylic Sheets.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

The status of the referenced Evaluation Report No. ER- 4063 dated May 2001, which is currently beyond its reexamination date is still valid. The validity of the evaluation report was verified with ICC

YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

RB:elcm
RR24785/wpd8.0
R07/12/07
2603.7

Attachment: ICC ES Legacy Report No. ER- 4063 (5 Pages).